

**STANDARDS PRESENTATION
TO
CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD**

Attachment No. 1

Page 1 of 1

PROPOSED STATE STANDARD,
TITLE 8, DIVISION 1, CHAPTER 4

Amend Section 1710(k)(2) to read:

§ 1710. Structural Steel Erection.

(k) Permanent Flooring—Skeleton Steel Construction in Tiered Buildings.

(2) At no time shall there be more than four floors or 48 feet, whichever is less, of unfinished bolting or welding above the foundation or uppermost permanently secured floor, except where structural integrity is maintained as a result of the design.

NOTE: Authority cited: Section 142.3, Labor Code. Reference: Sections 142.3, 7252, 7253, 7254, 7258, 7261, 7262 and 7266, Labor Code.